

Hey'di AS  
Line Greaser Andersen  
PB 13  
2017 Frogner  
Norway

15 April 2016  
Report no. K160637-6  
Page 1 of 2

## CERTIFICATE OF ANALYSIS

Sample : Hey'di Betongplan

Methods : GEV version Feb. 23, 2011  
ISO 16000-10, ISO 16000-3 and ISO 16000-6  
Air exchange rate: 0.5h  
Loading factor: 0.404 m<sup>2</sup>/m<sup>3</sup>

Result :

| Substances                         | Result after<br>3 days  | Result after<br>28 days |
|------------------------------------|-------------------------|-------------------------|
| Methanal (formaldehyde)            | < 0.2 µg/m <sup>3</sup> | < 0.2 µg/m <sup>3</sup> |
| Ethanal (acetaldehyde)             | < 0.2 µg/m <sup>3</sup> | < 0.2 µg/m <sup>3</sup> |
| Ammoniak                           | < 0.2 µg/m <sup>3</sup> | < 0.2 µg/m <sup>3</sup> |
| Acetic acid                        | < 0.2 µg/m <sup>3</sup> | < 0.2 µg/m <sup>3</sup> |
| Ethanol                            | < 0.2 µg/m <sup>3</sup> | < 0.2 µg/m <sup>3</sup> |
| 2-propanone (acetone)              | < 0.2 µg/m <sup>3</sup> | < 0.2 µg/m <sup>3</sup> |
| Butanal (butyraldehyde)            | < 0.2 µg/m <sup>3</sup> | < 0.2 µg/m <sup>3</sup> |
| 2-butenal (crotonaldehyde)         | < 0.2 µg/m <sup>3</sup> | < 0.2 µg/m <sup>3</sup> |
| 3-methylbutanal (isovaleraldehyde) | < 0.2 µg/m <sup>3</sup> | < 0.2 µg/m <sup>3</sup> |
| Propanal (propionaldehyde)         | < 0.2 µg/m <sup>3</sup> | < 0.2 µg/m <sup>3</sup> |
| 3-methylbenz-aldehyde              | < 0.2 µg/m <sup>3</sup> | < 0.2 µg/m <sup>3</sup> |
| 2-methylbenz-aldehyde              | < 0.2 µg/m <sup>3</sup> | < 0.2 µg/m <sup>3</sup> |
| 4-methylbenz-aldehyde              | < 0.2 µg/m <sup>3</sup> | < 0.2 µg/m <sup>3</sup> |
| Pentanal (valeraldehyde)           | < 0.2 µg/m <sup>3</sup> | < 0.2 µg/m <sup>3</sup> |

Result :

| Substances        | Result after<br>3 days  | Result after<br>28 days |
|-------------------|-------------------------|-------------------------|
| VOC               | < 0.5 µg/m <sup>3</sup> | < 0.5 µg/m <sup>3</sup> |
| TVOC (C6 – C16)   | < 0.5 µg/m <sup>3</sup> | < 0.5 µg/m <sup>3</sup> |
| TSVOC (C16 - C22) | < 0.5 µg/m <sup>3</sup> | < 0.5 µg/m <sup>3</sup> |

No agents according to IARC group 1 (carcinogens) was found.

Analysed by:

Toxicon AB



Daniel Kuster, lab ing.

Approved by:

Toxicon AB



Ann-Cathrin Simon, lab ing